

Highest PFOS & PFOA Levels for  
NBCMA testing in **2017**

	PFOS	PFOA	Combined	LHAL
<u>Well # 1</u>	9	10	19	70
<u>Well # 2</u>	8	10	18	70
<u>Well # 3</u>	8	9	17	70
<u>Well # 4</u>	13	11	24	70
<u>Well # 5</u>	0	0	0	70
<u>Well # 6</u>	0	5	5	70
<u>Well # 7</u>	10	10	20	70
<u>Well # 8</u>	12	11	23	70
<u>Well # 9</u>	9	8	17	70
<u>Well # 10</u>	7	7	14	70
<u>Well # 11</u>	6	8	14	70
<u>Well # 12</u>	6	9	15	70
<u>Well # 13</u>	5	5	10	70
<u>Well # 16</u>	0	4	4	70
<u>Well # 17</u>	8	8	16	70
<u>Antler Dr. PS</u>	0	2	2	70
<u>Bristol Rd. PS</u>	0	2	2	70

Highest level detected



# PFOS & PFOA

